



## Public Notice:

This is a public notice pursuant to Section 283.55 (1) (dm) of the Wisconsin State Statutes, in accordance with reporting requirements for Sanitary Sewer Overflow from the Department of Natural Resources.

On January 25, 2020 at approximately 4:30 pm, the force main developed a crack in a section of pipe in front of W11357 Hwy V. As a result the Sanitary Sewer Collection System had a fallout of 2700 Gallons. Repairs were made to the broken pipe on January 26, 2020. The area has since been pressure washed and will be cleaned up further once spring comes.

If you have any questions or concerns regarding this event please contact Superintendent Josh Brodeur at 608-393-3742. Or Email at [Harmokee52@yahoo.com](mailto:Harmokee52@yahoo.com)

*Connie R. Sears*

---

Posted Feb. 03, 2020  
By; Connie R. Sears  
Harmony Grove – Okee Joint Sewerage Commission  
Clerk – Treasurer

Posted to web site 02-03-2020  
[www.harmonygrove-okee.com](http://www.harmonygrove-okee.com)